

Public Safety

1.05-0262P Fire 08/26/05

On this date at approximately 0801 hours, a male USF staff member reported a small fire in a second floor wall of the Davis Hall construction area. The fire alarm was activated, the building was evacuated by USFPD, and the fire department responded to extinguish some smoldering insulation. The fire may have been caused by welding activities that took place earlier.

Officer Shaw investigated, turned over to Fire Marshal.

— *USF St. Petersburg* —

USF St. Petersburg - 140 Seventh Avenue South, St. Petersburg Florida 33701-5016 -- 727-553-4USF
Copyright © 2003, University of South Florida - Direct questions or comments about the web site to: www@stpt.usf.edu